

DRINKING WATER NOTICE

KENSTON MIDDLE SCHOOL Has Levels of TTHM above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TTHM. The average level of TTHM over the last four quarters was 0.089 mg/L. The standard for TTHM is 0.080 mg/L.

What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the following necessary steps:

We are flushing the system and retesting and the results were well below compliance numbers. Nothing needs to be done at this time other than this public notice. The system will be tested quarterly to make sure of compliance and regular flushing will take place.

TTHM's and HAA5 is a byproduct of chlorine.

_____ to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: Josh Goodridge

Phone Number: 440-543-2585

Mailing Address: 11484 E. Washington St, Chagrin Falls

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: 9-20-2018

PWSID: OH2844412 Facility ID: DS1

Monitoring Period: Third Quarter of 2018

DRINKING WATER NOTICE

KENSTON MIDDLE SCHOOL Has Levels of TOTAL HALOACETIC ACIDS (HAA5) above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TOTAL HALOACETIC ACIDS (HAA5). The average level of TOTAL HALOACETIC ACIDS (HAA5) over the last four quarters was 0.062 mg/L. The standard for TOTAL HALOACETIC ACIDS (HAA5) is 0.060 mg/L.

What should I do?

- You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the following necessary steps:

We are flushing the system and retesting was done. The results were well below compliance numbers. Nothing

needs to be done at this time other than this public notice. The system will be tested quarterly to make sure of compliance and regular flushing will take place.

HAA5 are a byproduct of chlorine.

_____ to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: Josh Goodridge

Phone Number: 440-543-2585

Mailing Address: 11484 E. Washington St Chagrin Falls 44023

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: 9-20-18

PWSID: OH2844412 Facility ID: DS1

Monitoring Period: Third Quarter of 2018